



Victoria F. Sheehan
Commissioner

THE STATE OF NEW HAMPSHIRE
DEPARTMENT OF TRANSPORTATION



William Cass, P.E.
Assistant Commissioner

June 1st, 2018

Mr. Frank Anzalone
PO Box 1016.
New London, NH 03257

Dear Mr. Anzalone,

We have reviewed your Application for a Driveway Permit for a proposed office building on Lot 73-047-000 on Route 114 in New London NH. Unfortunately, your application is denied for the following reason:

1. Inadequate Sight Distance – No more than 1 driveway shall be permitted for a lot of record unless there is all season safe distance of 400 feet in both directions along the highway. At the proposed driveway location the sight distance is less than 330 feet to the north. This lot already has an existing driveway; thus a second driveway cannot be approved.

Please be advised that the area labeled as “Gravel Parking Area” on existing conditions plan “Standard Property Survey” by Pierre J. Bedard and Associates has not been approved by NH DOT and needs to be removed and restored.

As previously discussed on the phone, Lot 73-046-000 is allowed a driveway access. If you would like to create a shared drive for Lot 73-046-000 and the proposed office building on Lot 73-047-00, please contact us and we would be happy to assist.

This driveway permit denial may be appealed by filing a request for an appeal hearing as outlines on page 16 of Policy for the Permitting of Driveways and Other Accesses to the State Highway System. Request for appeal hearing should be submitted in writing to:

State of New Hampshire
Department of Transportation, PO Box 483
Concord, NH 03302-0483
Attention: Hearing Examiner

Please feel free to contact us for further information as necessary.

Sincerely,

Chris Turgeon, PE
Assistant District Engineer
NH DOT District 2 Maintenance