



The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES



Thomas S. Burack, Commissioner

March 30, 2016

REQUEST FOR MORE INFORMATION

Bob Vachon
Colby-Sawyer College
541 Main Street
New London, NH 03257



RE: Alteration of Terrain Permit Application AoT 160303-028
Fine & Performing Arts Center, Map 85, Lot 33; New London, NH

Dear Applicant:

The Department of Environmental Services (DES) is in receipt of an application and supporting plans and information, for an Alteration of Terrain Permit for the above referenced project. After review of the information submitted, the following items need to be addressed in order for DES to make a **final determination** on the application for a permit:

1. Grading, Drainage and Utilities Site Plan, Sheet C201:

Please show more clearly how the roof runoff from the main building is getting to the micro-extended detention pond.

The drainage analysis shows the drip edges going to NB1 and the micro-extended detention pond. Please show this more clearly.

The plans don't show clearly where the discharge of CB N2 is located.

2. Drainage Analysis:

Pond 3P – please revise the length of the practice in the outlet device description.

Pond 4P – where is this shown on the plans.

3. Inspection and Maintenance Manual:

Please include an 11 x 17 plan showing where all of the BMPs are located.

Inspection Form – please review this form and be more specific as to what inspections are required for the micropool extended detention basin and which are for the stone drip edge. The NH Stormwater Manual, Volume 2 may have additional suggestions for maintenance requirements.

DES Web site: www.des.nh.gov

P.O. Box 95, 29 Hazen Drive, Concord, New Hampshire 03302-0095

Telephone: (603) 271-3503 • Fax: (603) 271-2982 • TDD Access: Relay NH 1-800-735-2964

4. Project CD:

Please note that, in accordance with Env-Wq 1503.20(e), within one week of a project being permitted the department requires that a CD be submitted which includes a copy of the plans and the drainage report (including the summary, drainage analysis, riprap sizing calculations, USGS map, etc), all in PDF format. This will assist DES in minimizing our long-term file storage space requirements.

Please respond to this request for more information letter in accordance with the provisions of Env-Wq 1503.15. Please include the file number on your response to this request, as well as a narration of the changes from the current application. Please be aware that in accordance with RSA 485-A:17, if all of the information requested above is not provided in a **single and complete** response within the next 120 days, **July 28, 2016, your file will be denied.** If you have any questions, do not hesitate to contact me at (603) 271-3568 or gloria.andrews@des.nh.gov.

Sincerely,



Gloria S. Andrews, P.E.
Alteration of Terrain Bureau

cc: New London Planning Board

cc: Will Davis, Horizons Engineering, Inc. (Email: wdavis@horizonsengineering.com)