From:	Jason Lyon
To:	Will Davis
Cc:	zoning@nl-nh.com
Subject:	Re: CSC Fine & Performing Arts Center
Date:	Friday, March 04, 2016 9:34:19 AM

Good morning Will,

Thank you for the update. Your proposal seams to be very reasonable and will address all of the New London Fire Department's concerns about access to this new arts center and water supply in the event of a fire.

Have a good weekend, Jay

****

Jason B. Lyon, Fire Chief
New London Fire Department
237 Main Street
(603) 526-6073

On Mar 3, 2016, at 3:47 PM, Will Davis <wdavis@horizonsengineering.com> wrote:

> Hi Jay,
>
> We met today with the design team and we will be proposing a 14' wide access drive along the rear of the building. It will connect to the existing access road and will extend all the way to the edge of the proposed art yard (±115 ft). So, the walkway that is currently shown as 6' wide will now be 14' and will be suitable for truck traffic.
>
> The existing fire hydrant along the stone wall between Ivey and the proposed building site is served by the 12" main that comes from the booster pump station on campus. We believe this hydrant will provide the appropriate protection for the building.
>
> If this is acceptable to you, will you please confirm by email that your concerns with access and hydrants have been addressed with these clarifications and additions? If not, please let me know so that we can discuss an agreeable solution prior to our submission to the planning board on Monday. Thanks!
>
> Will Davis, PE LEED AP
> Regional Office Manager
>
> Horizons Engineering, Inc.
> 176 Newport Road, PO Box 1825
> New London, NH 03257
> Cell: 802-291-1973
> Phone: 603-877-0116
> www.horizonsengineering.com