



TOWN OF
NEW LONDON, NEW HAMPSHIRE

375 MAIN STREET • NEW LONDON, NH 03257 • WWW.NL-NH.COM

NOTICE OF DECISION
New London Planning Board

RE: TODD & INGRID QUILLEN

MARCH 27, 2012

MAP 118, LOT 015-000

You are hereby notified that on this date, the New London Planning Board reviewed a request by Todd & Ingrid Quillen to approve a Stormwater Management Plan for their property at 295 Forest Acres Road. The purpose of the plan was to compensate for impervious surface added in the form of a gabled entry roof attached to the front of the building. The plan includes two dry wells, one at either front corner of the building, and a plunge pool and drywell on the east side of the building to accommodate the foundation drain sump pump discharge.

After hearing testimony regarding the applicant's proposal, **by unanimous vote, the New London Planning Board APPROVED the applicant's Stormwater Management Plan, allowing the applicant to add the gabled entry roof and increase the impervious surface percentage at the site to 20.4%.**

Tom Cottrill, Chairman

Board of Selectmen P: 603-526-4821 x 10 F: 603-526-9494	Town Administrator P: 603-526-4821 x 13 F: 603-526-9494	Town Clerk-Tax Collector P: 603-526-4821 x 11 F: 603-526-9494	Finance P: 603-526-4821 x 21 F: 603-526-9494	Assessing P: 603-526-4821 x 20 F: 603-526-9494
Planning/Zoning P: 603-526-4821 x 16 F: 603-526-9494	Fire Department P: 603-526-6073 F: 603-526-6079	Police Department P: 603-526-2626 F: 603-526-2782	Public Works P: 603-526-6337 F: 603-526-9662	Recreation P: 603-526-4821 x 14 F: 603-526-9494