



The State of New Hampshire
Department of Environmental Services



Thomas S. Burack, Commissioner

APPROVAL FOR CONSTRUCTION OF INDIVIDUAL SEWAGE DISPOSAL SYSTEM (ISDS)

AS AUTHORIZED BY THE NH DEPARTMENT OF ENVIRONMENTAL SERVICES, WATER DIVISION PURSUANT TO RSA 485-A, WATER POLLUTION AND WASTE DISPOSAL AND ENV-WQ 1000, SUBDIVISION AND INDIVIDUAL SEWAGE DISPOSAL SYSTEM DESIGN RULES.

APPLICATION APPROVAL DATE: 8/10/2015

APPROVAL NUMBER: eCA2015081007

I. PROPERTY INFORMATION

Address: 18 SUTTON ROAD
NEW LONDON NH 03257
Subdivision Approval No.: PRE-1967
Subdivision Name:
County: MERRIMACK
Tax Map/Lot No.: 122/2
Registry Book/Page No.: 3030/128
Probate Docket No.:

II. OWNER INFORMATION

Name: SANDRA ROWSE
Address: 18 SUTTON RD
NEW LONDON NH 03257

III. APPLICANT INFORMATION

Name: CLD CONSULTING ENGINEERS
Address: 28 GATES ST
WHITE RIVER JCT VT 05001

IV. DESIGNER INFORMATION

Name: CHARLES I HIRSHBERG
Address: 22 PINE RIDGE RD
SUNAPEE NH 03782
Permit No.: 00377

V. SPECIFIC TERMS AND CONDITIONS: Applicable to this Approval for Construction

A. TYPE OF SYSTEM: ENVIROSEPTIC

B. NO. OF BEDROOMS: 10

C. APPROVED FLOW: 1500 GPD

D. OTHER CONDITIONS AND WAIVERS:

1. This approval is valid for 4 years from date of approval, per Env-Wq 1003.02.
2. Approved for (two) 5-bedroom apartments; total flow 1500gpd.
3. Approved with a municipal water supply only.
4. The following waivers have been approved:
 - A. Rule: Env-Wq 1010 Section: 12 Multiple Tanks

Darren K. King
Subsurface Systems Bureau

VI. GENERAL TERMS AND CONDITIONS: Applicable to all Approvals for Construction

- A. This Approval for Construction is issued to construct the ISDS as identified on Page 1 of this Approval.
- B. This Approval is valid until 8/10/2019, unless an Approval for Operation has been granted.
- C. By exercising any rights under this approval, the parties have agreed to all terms and conditions.
- D. No liability is incurred by the State of New Hampshire by reason of any approval of any Approval for Construction. Approval by the Department of Environmental Services of sewage and waste disposal systems is based on plans and specifications supplied by the Applicant.
- E. The system must be constructed in strict accordance with the approved plans and specifications.
- F. The installed system must be left uncovered and cannot be used after construction until it is inspected and has received an Approval for Operation of Individual Sewage Disposal System (ISDS) by an authorized agent of the Department.
- G. This system must be installed by an installer holding a valid permit. An owner may install the system for his/primary domicile.
- H. This Approval for Construction does not supersede any equivalent or more stringent local ordinances or regulations. State standards are minimal and must be met statewide.

WORK NUMBER: 201502598
APPROVAL NUMBER: eCA2015081007
RECEIVED DATE: July 9, 2015
TYPE OF SYSTEM: ENVIROSEPTIC
NUMBER OF BEDROOMS: 10